

**Government of Rajasthan**

**Rajasthan Health Systems Development Project  
RHSDP Block, Swasthya Bhawan,  
Tilak Marg,C-Scheme  
Jaipur-302005**

**Tel.: 0141-5110730  
0141-2228778**

**Fax: 0141-2228778**

No. F.2 ( )/RHSDP/EPMC/2010/4820

Date: 3-11-2010

**To,**  
**M/s -----**

-----

-----

**Subject:** Minutes of Pre Bid Conference

**Reference:** 1-Pre Bid Meeting held on 25-10-2010

2- IFB No. F.2 (500)/RHSDP/EPMC/2010/ NCB-B Dated 6-10-2010

Please refer the above cited subject.

A pre bid conference was held on 25-10-2010 in reference to above mentioned IFB for procurement of equipment for drug warehouses through National Competitive Bidding (NCB).

The minutes of pre bid conference is enclosed herewith.

Please acknowledge the receipt.

**-sd-**

**Sr. Accounts Officer  
RHSDP. Jaipur.**

**Encl.:** As above

**RHSDP Block,  
Swasthya Bhawan,  
Tilak Marg, C-Scheme, Jaipur-302005**

**Tel: 0141-5110730/ 5110739  
Fax : 0141- 2228778  
Email: [rhsdp\\_raj@yahoo.co.in](mailto:rhsdp_raj@yahoo.co.in)**

**Minutes of Pre -Bid -Conference**

**Ref:** IFB No. F.2 (500)/RHSDP/EPMC/2010/ NCB-B

**Dated:** 6-10-2010

**Date:** 25-10-2010

**Time:** 14:30 hrs

**Venue:** Conference Room : PMU

A pre bid conference was held on 25-10-2010 in reference to NCB for procurement of equipment for drug warehouses. The prospective bidders / bidder's authorized representatives were attended the pre-bid conference. It was asked in the pre bid conference form the prospective bidders / bidder's authorized representatives to submit their queries in writing.

The queries submitted by the prospective bidders / bidder's authorized representatives and the responses are as follows:

<b>Sr. No.</b>	<b>Description</b>	<b>Queries</b>	<b>Response</b>
1	Technical Specification of Hydraulic Hand Pallet Trucks	Please clarify the Width Overall Fork and Fork length	Please refer the Section VI Schedule of Requirements Technical Specifications of Hydraulic Hand Pallet Trucks. Please read the following: Width Overall Fork: 540 mm Fork length: 1150 mm
2	Technical Specification of Split Type Air Conditioner	Please clarify the requirement of Air Conditioner whether it is Multi split type or split type air conditioner.	Please refer the Section VI Schedule of Requirements Technical Specifications of (1.5 Tr. Split Type Air Conditioner with Stabilizer). This is not a Multi Split Type Air Conditioner. The technical specifications shall read as Split Type Air Conditioner with Stabilizer.
3	Technical Specification of Split Type Air Conditioner	Please clarify the gas requirement detail for operating compressor unit.	Please refer the Section VI Schedule of Requirements Technical Specifications of Split Type Air Conditioner whereby it has been mentioned the requirements.